



## Environmental and Laboratory Services

### Dover Location:

90 1/2 West Blackwell St., Dover, NJ 07801  
Phone: (973) 989-0010, Fax (973) 989-0156

### Marlboro Location:

8A Railroad Ave, Marlboro, NJ 07746  
Phone: (732) 308-3500, Fax (732) 308-3503

Date: July 25, 2024  
Client: Frelinghuysen Elementary School  
Address: 780 Route 94  
Newton, NJ 07860

PWSID#: NJ2106307

Project Location:

## Analytical Results

Sample Matrix: Drinking Water Lab Sample Number: 240624053-001  
Sample Location: Kindegarten BR DS Customer Sample Number:  
Sampled By: Client  
Sample Date/Time: 7/18/2024 6:53

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	SM3111B	0.993	mg/L	1.3	7/23/2024	11:03	KJ	0.05	1
Lead-1st Draw	SM3113B	4.86	µg/L	15	7/24/2024	18:10	BPD	2	1

Sample Matrix: Drinking Water Lab Sample Number: 240624053-002  
Sample Location: Kitchen Sink #1 DS Customer Sample Number:  
Sampled By: Client  
Sample Date/Time: 7/18/2024 6:58

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	SM3111B	0.819	mg/L	1.3	7/23/2024	11:04	KJ	0.05	1
Lead-1st Draw	SM3113B	5.94	µg/L	15	7/24/2024	18:16	BPD	2	1

Frelinghuysen Elementary School

Sample Matrix: Drinking Water Lab Sample Number: 240624053-003  
 Sample Location: Kitchen Sink #2 DS Customer Sample Number:  
 Sampled By: Client  
 Sample Date/Time: 7/18/2024 7:01

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	SM3111B	0.855	mg/L	1.3	7/23/2024	11:04	KJ	0.05	1
Lead-1st Draw	SM3113B	4.82	µg/L	15	7/24/2024	18:22	BPD	2	1

Sample Matrix: Drinking Water Lab Sample Number: 240624053-004  
 Sample Location: Boys BR New Wing DS Customer Sample Number:  
 Sampled By: Client  
 Sample Date/Time: 7/18/2024 7:06

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	SM3111B	0.933	mg/L	1.3	7/23/2024	11:04	KJ	0.05	1
Lead-1st Draw	SM3113B	5.68	µg/L	15	7/24/2024	18:28	BPD	2	1


Sample Matrix: Drinking Water Lab Sample Number: 240624053-005  
 Sample Location: Room 113 Sink DS Customer Sample Number:  
 Sampled By: Client  
 Sample Date/Time: 7/18/2024 7:11

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Copper-1st Draw	SM3111B	0.406	mg/L	1.3	7/23/2024	11:05	KJ	0.05	1
Lead-1st Draw	SM3113B	6.95	µg/L	15	7/24/2024	18:34	BPD	2	1

Frelinghuysen Elementary School  
NJ Lab ID# 14013 (Dover)  
NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.  
Any method followed by an asterisk (\*) was analyzed by the Agra-Marlboro laboratory.  
All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the  
New Jersey Department of Environmental Protection.

  
\_\_\_\_\_  
Michael J Furrey, President

\_\_\_\_\_  
July 25, 2024